

2014 ANNUAL DRINKING WATER QUALITY REPORT
TOWN OF MONTVERDE
PWS ID: 3350847

THIS REPORT IS BEING DELIVERED TO EACH RESIDENT WITH THE MONTHLY NEWSLETTER.

We are pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is the Floridian Aquifer, we treat our water with chlorination to disinfect and feed a polyphosphate for corrosion control.

In 2014 the Department of Environmental Protection performed a source Water Assessment on our system. The assessment was conducted to provide information about any potential sources of contamination in the vicinity of our wells. There is 2 potential sources of contamination identified for this system with a moderate susceptibility level. The assessment results are available on the FDEP Source Water Assessment and Protection Program website at <http://www.dep.state.fl.us/swapp>.

We are pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please Plant Technicians at (352)787-2944. We encourage our valued customers to be informed about their water utility.

THE TOWN OF MONTVERDE routinely monitors for contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1st to December 31st 2014. Data obtained prior to January 1, 2014 and presented in this report are from the most recent testing done in accordance with the laws, rules and regulations.

"As authorized and approved by EPA, the state has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of our data (e.g., for organic contaminants), though representative, is more than a year old."

In the table shown, you may find unfamiliar terms and abbreviations. To help you better understand these terms, we have provided the following definitions:

Maximum Contaminant Level or MCL: The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Picocuri Per Liter (pCi/L): Measure of the radioactivity in water.

Treatment Technique (TT): A required process intended to reduce the level of contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL): The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Not Applicable (N/A): Does not apply.

“ND” means not detected and indicates that the substance was not found by laboratory analysis.

Parts Per Million (ppm) or Milligrams Per Liter (MG/L): One part by weight of analyte to 1 million parts by weight of the water sample.

Parts Per Billion (ppb) or Micrograms Per Liter (ug/l): One part by weight of analyte to 1 billion parts by weight of the water sample.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- (E) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. TOWN OF MONTVERDE is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

.....

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800)426-4791.

.....

Please call our office if you have any questions.

PLEASE NOTE: TOWN OF MONTVERDE CCR FOR YEAR 2013 WAS NOT SUBMITTED ON TIME AND WAS CONSIDERED LATE AS IT WAS NOT RECEIVED UNTIL AFTER AUGUST 10, 2014. HOWEVER, THE ENCLOSED CCR FOR YEAR 2014 HAS BEEN SUBMITTED IN A TIMELY MANNER.

TOWN OF MONTVERDE

PWS ID: 3350847

Water Quality Test Results

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCL G	MCL	Likely Source of Contamination
<u>Radioactive Contaminants</u>							
Alpha Emitters (pCi/L)	9/2012	N	3	ND-3	0	15	Erosion of natural deposits

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
<u>Inorganic Contaminants</u>							
Antimony (ppb)	9/2012	N	0.3	ND-0.3	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic (ppb)	9/2012	N	2.4	ND-2.4	0	10	Erosion of natural deposits; runoff from orchards, runoff from glass and electronics production wastes
Barium (ppm)	9/2012	N	0.0088	.0071-.0088	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Nitrate (as Nitrogen) (ppm)	#1 – 7/2014	N	1.88	N/A	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
	#2 – 7/2014	N	0.303				
Fluoride (ppm)	9/2012	N	0.16	0.14-0.16	4	4.0	Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at optimum levels between 0.7 and 1.3 ppm
Chromium (ppb)	9/2012	N	2	1.7-2	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Nickel (ppb)	9/2012	N	0.7	ND-0.7	N/A	100	Pollution from mining and refining operations. Natural occurrence in soil.
Sodium (ppm)	9/2012	N	5	4.3-5	N/A	160	Salt water intrusion leaching from soil
Selenium (ppb)	9/2012	N	3.1	1.2-3.1	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Nitrates: As a precaution we always notify physicians and health care providers in this area if there is ever a higher than normal level of nitrates in the water supply.

TTHMs and Stage 1 Disinfectants/Disinfection By-Products (D/DBP) Contaminants

For bromate, chloramines, or chlorine, the level detected is the the highest running annual average (RAA), computed quarterly, of monthly averages of all samples collected. For haloacetic acids or TTHM, the level detected is the highest RAA, computed quarterly, of quarterly averages of all samples collected if the system is monitoring quarterly or is the average of all samples taken during the year if the system monitors less frequently than quarterly. Range of Results is the range of individual sample results (lowest to highest) for all monitoring locations, including Initial Distribution System Evaluation (IDSE) results as well as Stage 1 compliance results.

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Chlorine (ppm)	1-12/2014	N	0.93	0.85-1.15	MRDLG = 4	MRDL = 4.0	Water additive used to control microbes
Haloacetic Acids (five) (HAA5) (ppb)	#1 -8/2014	N	6.00	N/A	N/A	MCL = 60	By-product of drinking water disinfection
	#2 -8 /2014	N	1.96				
TTHM [Total trihalomethanes] (ppb)*	#1 -8/2014	N	31.0	N/A	N/A	MCL = 80	By-product of drinking water disinfection
	#2-8/2014	N	6.1				

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	AL Violation Y/N	90th Percentile Result	No. of sampling sites exceeding the AL	MCLG	AL (Action Level)	Likely Source of Contamination
<u>Lead and Copper (Tap Water)</u>							
Copper (tap water) (ppm)	8/2012	N	0.11	0	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb)	8/2012	N	1.8	1	0	15	Corrosion of household plumbing systems, erosions of natural deposits

Lead in drinking water is rarely the sole cause of lead poisoning, but it can add to a person's total lead exposure. All potential sources of lead in the household should be identified and removed, replaced or reduced.