



1 LIGHTING PLAN - ELECTRICAL NORTH

0 4' 8' 16' 24'

1/8" = 1'-0"

LIGHT FIXTURE SCHEDULE			
TYPE	MANUFACTURER & PART NUMBER	DESCRIPTION	LAMPS (W)
A	LITHONIA 2RTL2 20L LP830	2X2 RECESSED LIGHTING FIXTURE	20.1 W
AE	LITHONIA 2RTL2 20L LP830 E10WLCP	2X2 RECESSED LIGHTING FIXTURE	20.1 W
B	HE WILLIAMS 8CR-TL-L20/835-DIM-UNV	8" LED ROUND CEILING DOWNLIGHT SURFACE CEILING MOUNT	19.6 W
BE	HE WILLIAMS 8CR-TL-L20/835-EM/10W-DIM-UNV	8" LED ROUND CEILING DOWNLIGHT SURFACE CEILING MOUNT	19.6 W
CE	LITHONIA CLX L48 5000LM HEF FDL MVOLT 30K 80CRI E10WLCP	EME 1x8 H LED STRIP LIGHT	31.6 W
D	MARK ARCHITECTURAL LIGHTING MGLP 24IN 80CRI 35K 1500LM	2' PENDENT LIGHT	15 W
E	MARK ARCHITECTURAL LIGHTING MGLP 36IN 80CRI 35K 6000LM	3' PENDENT LIGHT	64 W
G	HALO LIGHTING HC6 10D010	6" LED ROUND CEILING DOWNLIGHT SURFACE CEILING MOUNT	10.1W
GE	HALO LIGHTING HC6 10D010REM7	6" LED ROUND CEILING DOWNLIGHT SURFACE CEILING MOUNT	10.1W
I	LITHONIA 2RTL2 33L LP830	2X2 RECESSED LIGHTING FIXTURE	37 W
IE	LITHONIA 2RTL2 33L LP830 E10WLCP	2X2 RECESSED LIGHTING FIXTURE	37 W
I2	LITHONIA 2TLX2 33L LP830	2X2 SURFACE LIGHTING FIXTURE	37 W
IE2	LITHONIA 2TLX2 33L LP830 E10WLCP	2X2 SURFACE LIGHTING FIXTURE	37 W
X	LITHONIA EDGR	EXIT SIGN, EXTRUDED BRUSHED ALUMINUM FINISH WITH GREEN LED SELF-POWERED, INTEGRAL 90 MINUTE BATTERY, 120/277 V CEILING, WALL & END MOUNTING	3.8-4.5W
EM	COOPER SEL60R10SD	EMERGENCY WALL PACK LIGHT	3.5W
H	ACTUITY BRANDS WEDGE2 LED P1 80CRI 27K T4M MOVLT SRM E10WH NLTAIR2 PIR FINISH TBD	WALL SCONCE	12W
S	PHILIPS B08CK9LMH9	LIGHT STRIP PLUS BASE V5 80 INCH HUE AND COLOR AMBIANCE	3.04W/FEET
F	HAVELLS FHCMOURARB52	CEILING FAN WITH LIGHT FIXTURE	70 W
J	LITHONIA HGX LED 3RH ALO SSW2 120 PE WH	LED FLOOD LIGHT	25W

- CONTRACTOR SHALL PROVIDE SUBMITTAL OF ALL FIXTURES TO OWNER AND ARCHITECT. SUBMITTAL SHALL BE APPROVED BY OWNER, ARCHITECT AND ENGINEER PRIOR TO ORDERING ANY FIXTURES. IT IS THE RESPONSIBILITY OF THE LIGHTING VENDOR TO ENSURE OWNER & ARCHITECT HAVE SIGNED OFF ON SUBMITTALS.
- ANY SUBSTITUTION OF FIXTURES WILL REQUIRE A FULL PHOTOMETRIC ANALYSIS TO BE PROVIDED FOR ALL SUBSTITUTED AREAS. LIGHTING VENDOR/DISTRIBUTOR WILL BE RESPONSIBLE FOR GATHERING AND EVALUATING DATA TO MATCH INTENDED FIXTURE PHOTOMETRIC RESULTS. SUBSTITUTED FIXTURES WILL NOT BE APPROVED WITHOUT PHOTOMETRIC PROVIDED WITH SUBMITTAL.
- SUBSTITUTION OF LIGHT FIXTURES SHALL BE PRESENTED FIFTEEN DAYS PRIOR TO BID. ANY ADDITIONAL ENGINEERING COST FOR RE-WORK OR EXTRA SUBMITTAL EVALUATION FOR SUBSTITUTIONS SHALL BE PAID FOR BY GENERAL CONTRACTOR.

KEY NOTES

- EXTERIOR LIGHTS SHALL BE CONTROLLED VIA PHOTOCELL/ASTRONOMICAL TIMECLOCK.

HACKENBERG ENGINEERING

Hackenberg Engineering
PO Box 1886
Winter Park, FL 32790

REVISIONS

**HELEN LEHMANN
MONTVERDE LIBRARY**
17435 5TH STREET
MONTVERDE, FL 34756

PERMIT SET

GatorSketch
ARCHITECTS & PLANNERS
A200002010
1000 EAST HWY 50 SUITE 201A, CLEMONT, FL 34711
PH: (407) 968-5877 FAX: (888) 958-8114
Web Site: www.gatorsketch.com

SIGN DATE

COPYRIGHT © 2023
GATORSKETCH CORP.
THIS DRAWING IS PROTECTED BY
COPYRIGHT LAWS OF THE
UNITED STATES. NO PART OF THIS
DESIGN OR THIS DOCUMENT,
INCLUDING ELECTRONIC MEDIA,
MAY BE REPRODUCED,
TRANSMITTED, COPIED, OR
OTHERWISE USED FOR
CONSTRUCTION PURPOSES
WITHOUT EXPRESSED WRITTEN
PERMISSION OF THE DESIGN
PROFESSIONAL. VIOLATORS WILL
BE SUBJECT TO LEGAL
PROSECUTION TO THE FULLEST
EXTENT OF THE LAW.

LIGHTING
PLAN-
ELECTRICAL
E-101
ISSUE DATE 09-26-2023

JOB # GC-22-010